



VAPI GREEN ENVIRO LIMITED

Formerly known as Vapi Waste & Effluent Mgt. Co. Ltd.

VIA House, Plot No. 135, Char Rasta, GIDC VAPI - 396 195, Gujarat, INDIA
 Mob.: 9714000828 | Tel.: (0260) 2428950, Telefax : (0260) 2429950 | Email : admin@vgelvapi.com
 Website : www.vgelvapi.com | www.coevapi.com | CIN : U74210GJ1997GAP031525

Date: 05-08-2024

CORRIGENDUM

Tender for Supply and Installation of **80 KW Solar Panel for Electric Power Generation** at COE Site, Vapi was published on www.vgelvapi.com on date 26-07-2024. Below Points were discussed and summarized during pre-bid meeting on date 05-08-2024 at COE.

Technical Points:

1	2	3	4
Sr. No.	Issue	Quarry	Reply by Vapi Green Enviro Limited
1	Part A, Point 5, Page 8 of 13	Solar PV Module, Module Capacity Parties has inquired about DCR OR Non-DCR Panel	VGEL have decided to install Non DCR panel . Solar Panel should be ALMM Approved .
2	Part A, Point 6, Page 9 of 13	Inverter Make: Fronius, ABB, Sungrow	VGEL have finalized Make: Fronius and ABB for Inverter .
3	Part A, Point 6, Page 9 of 13	Over Capacity of Inverter:40%	VGEL have decided to install 20 % Extra Capacity of Inverter for 80 KW, and 5 years warranty of Inverter with additional 10 years warranty for availability of spares.
4	Part A, Point 13, Page 10 of 13	Earthing: Cable Size not specified	VGEL has given specification for Earthing, Copper flexible Cable to be used of size 10 Sq. mm x 1 core And lighting arrester Cable Size 16 sq Sq. mm x 1 core cable. OK Accepted.
5	Part A, Point 7, Page 9 of 13	Structure: Make Indiana	Hott dip Galvanized Iron Structure to be Installed. VGEL will accept structural 80 Micron hot deep galvanizing of Tata or Indian Make. Required to submit Test Certificate of hot dip Galvanizing and MOC)
6	Part A, Point 12, Page 10 of 13	ACDB, DCDB Box: Rating IP 68	IP 68





VAPI GREEN ENVIRO LIMITED

Formerly known as Vapi Waste & Effluent Mgt. Co. Ltd.

VIA House, Plot No. 135, Char Rasta, GIDC VAPI - 396 195, Gujarat, INDIA
Mob.: 9714000828 | Tel.: (0260) 2428950, Telefax : (0260) 2429950 | Email : admin@vgeivapi.com
Website : www.vgeivapi.com | www.coevapi.com | CIN : U74210GJ1997GAP031525

Commercial Points:	
7	Page No. 6 of 13 Guarantee / Defect Liability Period as per Tender Guarantee period 5 Years for whole System 25 Years Unconditional warranty of Solar Panel
8	New Point Light Bill Copy to be attached with Corrigendum
9	New Point GEDA Approval of earlier project to be given
10	New Point All Liaison work and Approval Work as per Part B of Technical Specification, Page 11 of 13
	10 years unconditional warranty for Solar Panel & 25 years performance warranty of Solar Panel. In Inverter company give 5 yrs of warranty only. For Extended warranty of Invertor, after completing 4 yrs, company decide for the period of extended warranty at Extra Cost. Solar Panel should be ALMM Approved.
	OK Copy attached
	To be given to selected party only after issue of Work order.
	All Liaison work and Approval Work of Project will be done by selected party of Tender. Only Government Fees will be paid by VGEL against submission of original copy of Payment Receipt.

Additional Queries:

(1) Bidders are requested to submit their offer within extended time limit on or before last submission at 13:00 PM on date 22-08-2024 at our Head Office.

Vapi Green Enviro Limited,
Plot No. 135, VIA House,
Char Rasta, GIDC, Vapi - 396195



A phase

Dakshin Gujarat Vij Company Ltd.

Reg. Off: Nana varachha Road, Nr. Kapodra Char Rasta, Surat-395006
 CIN:U40102GJ2003SGC042909 GSTIN:24AABCD8912C1Z3 PAN NO: AABCD8912C Website:http://www.dgvcl.com

DG CL

HT BILL FOR THE MONTH OF :JUL-2024

By RPAD/Hand Delivery No.

VAPI GREEN ENVIRO LTD.
 CENTRE OF EXCELLENCE, S. NO. 735/P, 863/P, 864/P
 G.I.D.C.VAPI

OFFICE OF EXEC. ENGINEER

DGVCL Division Office

Date: 18-07-2024



SCAN to PAY

Division Office Email id: Phone No: Cons. GSTIN: 24AAACV8289P1ZH

Consumer No:	Tarrif	Contract Demand	85% Contract Demand	Actual Max. Demand	Billing Demand	Excess Cont. DMD	SD Cash	Bank Guarantee
38414	HTP-I	200	170	65	170		918107	0.00
Supp Voltage	KWH	KVAH	KVARH	Avg PF	MF	Actual Max DMD during day		PF Indicator
11	14568	14601	90	.997	3			
Meter No:	Make	CTPT Make	CTPT Srno	CT Ratio	PT Ratio	Meter Constant	MC/MF/CD/TF	Meter Status
CHBD0189	LNT		3					Normal
Current R	82175	82534	1711	26464	25499	0	AMD DAY	AMD NIGHT
Previous R	77319	77667	1681	24902	24542			
Difference	4856	4867	30	1562	957			
Diff*MF	14568	14601	90	4686	2871			
Old Met Cons.								
Enhanced Unit								

CONSUMPTION DETAILS

A.Total Units	B.Night Units	C.TOU	D.1/3 Of Units in A	E.Night Concession Units	F.Connection Date	G.Consumer Type
14568	2871	4686	4856	2871	12-01-2008	
H.Recoverable SD	I.Seasonal Status	J.ED Exemption Upto	K.Details of Adjustments			CHQ DISHONOUR DT

CALCULATION OF CHARGES

Demand Charges	DMD in KVA	Rate per KVA	Amount Rs						
1st 500 KVA	170	150	25500	Electricity Duty	KWH	Consumption Charges	ED Rate	Amount	Exempted Amount
2nd 500 KVA	0	0	0		14568	126030.11	.2	25206.02	0
Next	0	0	0						
Excess DMD	0	0	0						
Tot Demand	170		25500						
SET OFF DETAILS									
Energy Charges	KWH	Rate	Amount	Total->	Wind Energy	CFP	Open Access		
Night Rebate	2871	0	0	Units	0	0	0		
Fuel charge	14568	2.85	41518.80	Amount					
PF Rebate	58272	-2.35%	-1369.39	Adj (Credit)	0	0	0		
EHV Rebate	58272.00	0.00	0.00	Adj (Debit)		0	0		
TOU	4686	0.45	2108.70	AMG Charges					
GT Charges	14568	1.5	0.00	CGST:		SGST:			
Tot Consumption Charge			126030.11						

SUMMARY OF CHARGES

Demand Charge	Energy Charge	Fuel Surcharge	PF Adj/Rebate	Night Rebate	EHV Rebate	Time Of Use Charges	GT Charges	Tot Consumption Charge	
25500.00	58272.00	41518.80	-1369.39	0.00	0.00	2108.70	0.00	126030.11	
Electricity Duty	Meter Charges	Cross Subsidy	Wheeling Charges	Parallel Operation Charges	Current MOnth's Bill	Outstanding Arrears			
25206.02	0.00				151236.13	0.00			
Delayed Payment Charges	Adv.Payment / Adjust.	Net Payable	TCS	Total Payable	PREV.BILL TCS Cr	Reading Date	Bill Date	Due Date	Freeze Amount
0.00	1034.22	152270.35	153.00	152423.35		16-07-2024	18-07-2024	29-07-2024	0.00

Amount in Words: One Lakhs Fifty Two Thousand Four Hundred And Twenty Three And Thirty Five Paise Only

Msg:TCS has been charged on the current bill as per provision of IT ACT

MORUN
 EXECUTIVE ENGINEER
 VAPI IND O&M

MC-Meter Change MF-Multiplication Factor CD-Contract Demand TF-Tariff Change
 FOR IMPORTANT NOTE PLEASE SEE OVERLEAF

RECEIVED

NO. 189